

Table of Contents

1.0	Introduction	1
2.0	Physical Description	3
2.1	Proposed Line.....	3
2.2	Existing Lines.....	3
3.0	Electric Field	4
3.1	Basic Concepts	4
3.2	Transmission-line Electric Fields.....	5
3.3	Calculated Values of Electric Fields.....	6
3.4	Environmental Electric Fields.....	7
4.0	Magnetic Field	8
4.1	Basic Concepts	8
4.2	Transmission-line Magnetic Fields	9
4.3	Calculated Values for Magnetic Fields	9
4.4	Environmental Magnetic Fields	10
5.0	Electric and Magnetic Field (EMF) Effects	13
5.1	Electric Fields: Short-term Effects.....	13
5.2	Magnetic Field: Short-term Effects.....	15
6.0	Regulations	16
7.0	Audible Noise	19
7.1	Basic Concepts	19
7.2	Transmission-line Audible Noise.....	20
7.3	Predicted Audible Noise Levels.....	20
7.4	Discussion	21
7.5	Conclusion.....	22
8.0	Electromagnetic Interference	22
8.1	Basic Concepts	22
8.2	Radio Interference (RI)	23
8.3	Predicted RI Levels	23
8.4	Television Interference (TVI)	23
8.5	Predicted TVI Levels	24
8.6	Interference with Other Devices	24
8.7	Conclusion.....	25
9.0	Other Corona Effects	25
10.0	Summary	25
	List of References Cited.....	27
	List of Preparers.....	31

List of Tables

Table 1	Possible configurations for Grand Coulee – Bell 500-kV transmission-line corridor	33
Table 2	Physical and electrical characteristics of lines in the Grand Coulee – Bell 500-kV transmission-line corridor	35
Table 3	Calculated peak and edge-of-right-of-way electric fields for the proposed Grand Coulee – Bell 500-kV line operated at maximum voltage by configuration	38
Table 4	Calculated peak and edge-of-right-of-way magnetic fields for the proposed Grand Coulee – Bell 500-kV line operated at maximum current by configuration	40
Table 5	States with transmission-line field limits	42
Table 6	Common noise levels	43
Table 7	Typical sound attenuation (in decibels) provided by buildings	43
Table 8	Predicted foul-weather audible noise (AN) levels at edge of right-of-way (ROW) for the proposed Grand Coulee – Bell 500-kV line	46
Table 9	Predicted fair-weather radio interference (RI) levels at 100 feet (30.5 m) from the outside conductor of the proposed Grand Coulee – Bell 500-kV line corridor ..	45
Table 10	Predicted maximum foul-weather television interference (TVI) levels at 100 feet (30.5 m) from the outside conductor of the proposed Grand Coulee – Bell 500-kV line corridor	46

List of Figures

Figure 1	Configurations for proposed Grand Coulee – Bell 500-kV line	47
Figure 2	Electric-field profiles for configurations of the proposed Grand Coulee – Bell 500-kV line under maximum voltage conditions	57
Figure 3	Magnetic-field profiles for configurations of the proposed Grand Coulee – Bell 500-kV line under maximum current conditions	62
Figure 4	Predicted foul-weather L ₅₀ audible noise levels from configurations of proposed Grand Coulee – Bell 500-kV line	67